


6" CLAY OR CONCRETE, <=10" PVC MAINS




8"+ CLAY OR CONCRETE, 12"+ PVC MAINS

CORE THE MAINLINE
AND INSTALL AN
INSERTA-TEE FITTING

PLAN VIEW


SEE RESOLUTION
NO. 104
FOR CLEANOUT
INFORMATION.



PROFILE VIEW

NOTES:

- 1 - BUILDING SEWERS MUST BE 4 INCH OR LARGER PIPE DIAMETER. PVC PIPE SHALL BE SDR-35 AND SHALL BE GREEN IN COLOR.
- 2 - FOR 6-INCH CLAY OR CONCRETE OR 10-INCH AND SMALLER PVC MAINLINES, SPLICE A FACTORY "WYE" INTO THE MAIN USING 2 SLIP/REPAIR OR STAINLESS STEEL SHIELDED SEWER REPAIR (SHEAR BAND) COUPLINGS (NO MORE THAN A 1/2-INCH GAP BETWEEN JOINTS). FLEXIBLE-TYPE COUPLINGS ARE NOT PERMITTED. THE COUPLINGS SHALL BE SHADED IN SALT FROM THE SPRINGLINE UP TO THE TOP OF THE INSERTA-TEE FITTING.
- 3 - A GLUE CAP OR PVC PUSH CAP IS REQUIRED AT THE END OF EACH BUILDING SEWER. "BRANDT" PLUGS ARE NOT ALLOWED.
- 4 - THE BEDDING MATERIAL SHALL BE 1-INCH GRADED GRAVEL, WELL HAUNCHED. IF THE NATIVE MATERIAL IS SAND, IT MAY BE USED, WELL HAUNCHED.
- 5 - THE MINIMUM COVER OVER THE TOP OF THE PIPE SHALL BE 3 FEET.



SCALE: NONE

ORIGINAL	
04/17/2019	LBH
REVISIONS	
07/02/2020	LBH
07/14/2020	LBH

SOUTH DAVIS SEWER DISTRICT

BUILDING SEWER CONNECTION TO SEWER MAIN (EXISTING SEWER)



SHEET:

114-3