



SECTION A

NOTE:

GROUT ONLY THE INLETS AND OUTLETS OF MANHOLE, AS SHOWN. GROUT WORK MUST BE DONE COMPLETELY FROM SHELF TO SHELF TO RECEIVE DISTRICT APPROVAL.

SCALE: NONE

ORIGINAL	
07/02/2020	LBH
REVISIONS	
07/14/2020	LBH

SOUTH DAVIS SEWER DISTRICT

GROUT DETAIL



SHEET:

114-5